

METROPOLITAN UTILITIES DISTRICT	Construction Standard	No: 3.1.1
	Obsolete Fire Hydrants	Page: 1 of 1
Prepared by: D.J. Satterfield		Supersedes: 1-14-09
Approved by: Jeff Schovanec		Effective: 7-30-14

General

Certain criteria have been established to effectively remove any obsolete or inferior hydrants from the distribution system.

Obsolete Hydrants

If the following hydrants are involved in a main extension or relocation project, they are not to be reused. They should be returned to the Stores department for parts or credit as CI scrap. Many of these hydrants are obsolete and parts are not available. Others are a poor quality of hydrant.

American Darling	M&H Non Traffic
American Standard	M&H Regent Traffic
American Traffic	Mueller, 4 ¼" Traffic
A.P Smith Traffic	Mueller, 5 ¼" Traffic
Clow 2500	Mueller 6"
Clow Contemporary	Paxton Mitchell (PM)
Corey	Waterous Non Traffic
Dresser Traffic	Waterous Traffic
Iowa, 4 ¼" two-way nozzle	Wood Hydrant, Kennedy
Kennedy 5 1/4" Traffic	Wood, New Style
M&H Lug Traffic	Wood, Old Style

Reusable Hydrants

If the following hydrants are part of a main extension or relocation project, they can be recovered or reused. If they are not needed on the project, they should be returned to the Stores department for credit.

East Jordan Iron Works 5CD250 WaterMaster
 Mueller Centurion Traffic
 Mueller Super Centurion 250
 Clow Medallion

*

If there are any questions or more information is needed, contact the Superintendent of Water Distribution.

* Revised Text



This Page Is Intentionally Left Blank