

**METROPOLITAN UTILITIES DISTRICT OF OMAHA  
REPORT OF WATER ANALYSIS**

Platte West Plant

Monthly Averages

Source: Finished Water

Date: April 2023

Temperature	<u>13.6</u>	° C
Turbidity (NTU)	<u>0.03</u>	Units
Total Organic Carbon	<u>1.7</u>	mg/L
Color	<u>2</u>	Units
Dissolved Oxygen (O <sub>2</sub> )	<u>5.6</u>	mg/L
Langelier Index	<u>1.13</u>	
UV-ABS @ 254 nm	<u>3.6</u>	ABS/m
Specific Conductance @ 25 °C	<u>395</u>	mmhos
Dissolved Solids (Calculated)	<u>330</u>	mg/L

Silica (SiO<sub>2</sub>) 29.9 mg/L

pH 8.93 mg/L

Alkalinity (CaCO <sub>3</sub> )		
Phenolphthalein (P)	<u>13</u>	mg/L
Total (M)	<u>124</u>	mg/L

Total Hardness (CaCO <sub>3</sub> )	<u>134</u>	mg/L
Carbonate	<u>124</u>	mg/L
Non-carbonate	<u>10</u>	mg/L

Nitrogen (N)		
Ammonia	<u>&lt;0.05</u>	mg/L
Nitrite	<u>&lt;0.02</u>	mg/L
Nitrate	<u>0.62</u>	mg/L

Chlorine (Cl <sub>2</sub> )		
Free Residual	<u>0.00</u>	mg/L
Total Residual	<u>2.10</u>	mg/L

Surfactants (MBAS) - mg/L

Trace Inorganics:		
Iron (total)	<u>&lt;0.02</u>	mg/L
Iron (dissolved)	<u>-</u>	mg/L
Manganese (total)	<u>0.01</u>	mg/L
Manganese (dissolved)	<u>-</u>	mg/L

Cations :			
Calcium	(Ca)	<u>40</u>	mg/L
Magnesium	(Mg)	<u>8.5</u>	mg/L
Sodium	(Na)	<u>30</u>	mg/L
Potassium	(K)	<u>9.1</u>	mg/L

Anions :			
Bicarbonate	(HCO <sub>3</sub> )	<u>120</u>	mg/L
Carbonate	(CO <sub>3</sub> )	<u>15.6</u>	mg/L
Hydroxide	(OH)	<u>&lt;0.1</u>	mg/L
Fluoride	(F)	<u>0.7</u>	mg/L
Chloride	(Cl)	<u>15</u>	mg/L
Bromide	(Br)	<u>0.02</u>	mg/L
Nitrite	(NO <sub>2</sub> )	<u>&lt;0.07</u>	mg/L
Nitrate	(NO <sub>3</sub> )	<u>2.75</u>	mg/L
Phosphate-ortho	(PO <sub>4</sub> )	<u>0.32</u>	mg/L
Sulfate	(SO <sub>4</sub> )	<u>59</u>	mg/L

Trace Inorganics :			
Aluminum	(Al)	<u>&lt;0.010</u>	mg/L
Copper	(Cu)	<u>0.001</u>	mg/L
Iron	(Fe)	<u>&lt;0.02</u>	mg/L
Lithium	(Li)	<u>0.019</u>	mg/L
Manganese	(Mn)	<u>0.01</u>	mg/L
Strontium	(Sr)	<u>0.268</u>	mg/L
Zinc	(Zn)	<u>&lt;0.005</u>	mg/L

Antimony	(Sb)	<u>&lt;1.0</u>	µg/L
Arsenic	(As)	<u>3.98</u>	µg/L
Barium	(Ba)	<u>70.1</u>	µg/L
Beryllium	(Be)	<u>&lt;1.0</u>	µg/L
Cadmium	(Cd)	<u>&lt;1.0</u>	µg/L
Chromium	(Cr)	<u>&lt;1.0</u>	µg/L
Lead	(Pb)	<u>&lt;1.0</u>	µg/L
Mercury	(Hg)	<u>-</u>	µg/L
Nickel	(Ni)	<u>&lt;1.0</u>	µg/L
Selenium	(Se)	<u>&lt;5.0</u>	µg/L
Thallium	(Tl)	<u>&lt;1.0</u>	µg/L

Bacteriological Quality : Distribution System  
Meets U.S.E.P.A. drinking water standards:  
TC - 0.36%; E. coli - Absent  
Giardia - N.D. Cryptosporidium - N.D.

Organics :			
Atrazine		<u>0.12</u>	µg/L
Metolachlor		<u>-</u>	µg/L

N. D. = Not Detected

***Raksha Chhetri***

Biologist I