

**METROPOLITAN UTILITIES DISTRICT OF OMAHA  
REPORT OF WATER ANALYSIS**

Platte South Plant

Monthly Averages

Source: Finished Water

Date: February 2024

Temperature	<u>11.9</u>	°C
Turbidity (NTU)	<u>0.05</u>	Units
Total Organic Carbon	<u>1.9</u>	mg/L
Color	<u>4</u>	Units
Dissolved Oxygen (O <sub>2</sub> )	<u>6.5</u>	mg/L
Langelier Index	<u>1.40</u>	
UV-ABS @ 254 nm	<u>5.1</u>	ABS/m
Specific Conductance @ 25 °C	<u>561</u>	µmhos
Total Dissolved Solids	<u>441</u>	mg/L

Silica (SiO<sub>2</sub>) 30.0 mg/L

pH 9.06 Units

Alkalinity (CaCO <sub>3</sub> )		
Phenolphthalein (P)	<u>21</u>	mg/L
Total (M)	<u>161</u>	mg/L

Total Hardness (CaCO <sub>3</sub> )	<u>176</u>	mg/L
Carbonate	<u>161</u>	mg/L
Non-carbonate	<u>15</u>	mg/L

Nitrogen (N)		
Ammonia	<u>&lt;0.05</u>	mg/L
Nitrite	<u>&lt;0.02</u>	mg/L
Nitrate	<u>1.28</u>	mg/L

Chlorine (Cl <sub>2</sub> )		
Free Residual	<u>-</u>	mg/L
Total Residual	<u>2.01</u>	mg/L

Surfactants (MBAS) - mg/L

Radioactivity :		
Gross Alpha & Beta	<u>-</u>	pCi/L
Iodine 131	<u>-</u>	pCi/L
Radium 226	<u>-</u>	pCi/L
Strontium 90	<u>-</u>	pCi/L
Tritium	<u>-</u>	pCi/L

Bacteriological Quality : Distribution System  
Meets U.S.E.P.A. drinking water standards:  
T. Coli - 0.00%; E. Coli - Absent  
Giardia - N.D. Cryptosporidium - N.D.

N.D. = Not Detected

Cations :			
Calcium	(Ca)	<u>51</u>	mg/L
Magnesium	(Mg)	<u>12</u>	mg/L
Sodium	(Na)	<u>54</u>	mg/L
Potassium	(K)	<u>7.5</u>	mg/L

Anions :			
Bicarbonate	(HCO <sub>3</sub> )	<u>145</u>	mg/L
Carbonate	(CO <sub>3</sub> )	<u>25.2</u>	mg/L
Hydroxide	(OH)	<u>&lt;0.1</u>	mg/L
Fluoride	(F)	<u>0.7</u>	mg/L
Chloride	(Cl)	<u>49</u>	mg/L
Bromide	(Br)	<u>0.02</u>	mg/L
Nitrite	(NO <sub>2</sub> )	<u>&lt;0.07</u>	mg/L
Nitrate	(NO <sub>3</sub> )	<u>5.67</u>	mg/L
Phosphate	(PO <sub>4</sub> )	<u>0.62</u>	mg/L
Sulfate	(SO <sub>4</sub> )	<u>59</u>	mg/L

Trace Inorganics :			
Aluminum	(Al)	<u>&lt;0.01</u>	mg/L
Copper	(Cu)	<u>0.001</u>	mg/L
Iron	(Fe)	<u>0.094</u>	mg/L
Lithium	(Li)	<u>0.019</u>	mg/L
Manganese	(Mn)	<u>&lt;0.001</u>	mg/L
Strontium	(Sr)	<u>0.316</u>	mg/L
Zinc	(Zn)	<u>&lt;0.005</u>	mg/L

Antimony	(Sb)	<u>&lt; 1.0</u>	µg/L
Arsenic	(As)	<u>3.56</u>	µg/L
Barium	(Ba)	<u>81.3</u>	µg/L
Beryllium	(Be)	<u>&lt; 1.0</u>	µg/L
Cadmium	(Cd)	<u>&lt; 1.0</u>	µg/L
Chromium	(Cr)	<u>&lt; 1.0</u>	µg/L
Lead	(Pb)	<u>&lt; 1.0</u>	µg/L
Mercury	(Hg)	<u>-</u>	µg/L
Nickel	(Ni)	<u>1.17</u>	µg/L
Selenium	(Se)	<u>&lt; 5.0</u>	µg/L
Thallium	(Tl)	<u>&lt; 1.0</u>	µg/L

Organics :			
Atrazine		<u>-</u>	µg/L
Metolachlor		<u>-</u>	µg/L

**Renate Alumbaugh**  
Water Analyst