

**METROPOLITAN UTILITIES DISTRICT OF OMAHA
REPORT OF WATER ANALYSIS**

Platte West Plant

Monthly Averages

Source: Finished Water

Date: May 2026

Temperature 15.5 °C
 Turbidity (NTU) 0.04 Units
 Total Organic Carbon 1.7 mg/L
 Color 1 Units
 Dissolved Oxygen (O₂) 4.7 mg/L
 Langelier Index 1.27
 UV-ABS @ 254 nm 4.7 ABS/m
 Specific Conductance @ 25 °C 413 mmhos
 Dissolved Solids (Calculated) 333 mg/L

Silica (SiO₂) 26 mg/L

pH 9.02 mg/L

Alkalinity (CaCO₃)
 Phenolphthalein (P) 18 mg/L
 Total (M) 133 mg/L

Total Hardness (CaCO₃) 139 mg/L
 Carbonate 133 mg/L
 Non-carbonate 6 mg/L

Nitrogen (N)
 Ammonia <0.05 mg/L
 Nitrite <0.02 mg/L
 Nitrate 0.55 mg/L

Chlorine (Cl₂)
 Free Residual 0.00 mg/L
 Total Residual 2.60 mg/L

Surfactants (MBAS) - mg/L

Trace Inorganics:
 Iron (total) <0.02 mg/L
 Iron (dissolved) - mg/L
 Manganese (total) <0.02 mg/L
 Manganese (dissolved) - mg/L

Cations :
 Calcium (Ca) 41 mg/L
 Magnesium (Mg) 9.0 mg/L
 Sodium (Na) 26 mg/L
 Potassium (K) 8.0 mg/L

Anions :
 Bicarbonate (HCO₃) 118 mg/L
 Carbonate (CO₃) 22 mg/L
 Hydroxide (OH) <0.1 mg/L
 Fluoride (F) 0.64 mg/L
 Chloride (Cl) 16 mg/L
 Bromide (Br) 0.02 mg/L
 Nitrite (NO₂) <0.07 mg/L
 Nitrate (NO₃) 2.44 mg/L
 Phosphate-ortho (PO₄) 0.37 mg/L
 Sulfate (SO₄) 64 mg/L

Trace Inorganics :
 Aluminum (Al) <0.01 mg/L
 Copper (Cu) <0.001 mg/L
 Iron (Fe) <0.02 mg/L
 Lithium (Li) 0.016 mg/L
 Manganese (Mn) <0.02 mg/L
 Strontium (Sr) 0.251 mg/L
 Zinc (Zn) <0.005 mg/L

Antimony (Sb) < 1.0 µg/L
 Arsenic (As) 3.97 µg/L
 Barium (Ba) 63.4 µg/L
 Beryllium (Be) < 1.0 µg/L
 Cadmium (Cd) < 1.0 µg/L
 Chromium (Cr) < 1.0 µg/L
 Lead (Pb) < 1.0 µg/L
 Mercury (Hg) - µg/L
 Nickel (Ni) <1.0 µg/L
 Selenium (Se) < 5.0 µg/L
 Thallium (Tl) < 1.0 µg/L

Bacteriological Quality : Distribution System
Meets U.S.E.P.A. drinking water standards:
TC - 0.00%; E. coli - Absent
Giardia - N.D. Cryptosporidium - N.D.

Organics :
 Atrazine 0.18 µg/L
 Metolachlor - µg/L

N. D. = Not Detected

Brent Paine
 Biologist I