

METROPOLITAN UTILITIES DISTRICT OF OMAHA
REPORT OF WATER ANALYSIS

Platte West Plant

Monthly Averages

Source: Finished Water

Date: July 2026

Temperature	<u>17.5</u>	° C
Turbidity (NTU)	<u>0.04</u>	Units
Total Organic Carbon	<u>1.7</u>	mg/L
Color	<u>1</u>	Units
Dissolved Oxygen (O ₂)	<u>5.8</u>	mg/L
Langelier Index	<u>1.13</u>	
UV-ABS @ 254 nm	<u>4.2</u>	ABS/m
Specific Conductance @ 25 °C	<u>405</u>	mmhos
Dissolved Solids (Calculated)	<u>308</u>	mg/L

Silica (SiO ₂)	<u>29</u>	mg/L
----------------------------	-----------	------

pH	<u>8.91</u>	mg/L
----	-------------	------

Alkalinity (CaCO ₃)		
Phenolphthalein (P)	<u>14</u>	mg/L
Total (M)	<u>108</u>	mg/L

Total Hardness (CaCO ₃)	<u>126</u>	mg/L
Carbonate	<u>108</u>	mg/L
Non-carbonate	<u>18</u>	mg/L

Nitrogen (N)		
Ammonia	<u><0.05</u>	mg/L
Nitrite	<u><0.02</u>	mg/L
Nitrate	<u>0.44</u>	mg/L

Chlorine (Cl ₂)		
Free Residual	<u>0.10</u>	mg/L
Total Residual	<u>2.60</u>	mg/L

Surfactants (MBAS)	<u>-</u>	mg/L
--------------------	----------	------

Trace Inorganics:		
Iron (total)	<u><0.02</u>	mg/L
Iron (dissolved)	<u>-</u>	mg/L
Manganese (total)	<u><0.02</u>	mg/L
Manganese (dissolved)	<u>-</u>	mg/L

Cations :		
Calcium	(Ca)	<u>36</u> mg/L
Magnesium	(Mg)	<u>5.3</u> mg/L
Sodium	(Na)	<u>30</u> mg/L
Potassium	(K)	<u>8.6</u> mg/L

Anions :		
Bicarbonate	(HCO ₃)	<u>98</u> mg/L
Carbonate	(CO ₃)	<u>17</u> mg/L
Hydroxide	(OH)	<u><0.1</u> mg/L
Fluoride	(F)	<u>0.67</u> mg/L
Chloride	(Cl)	<u>16</u> mg/L
Bromide	(Br)	<u>0.02</u> mg/L
Nitrite	(NO ₂)	<u><0.07</u> mg/L
Nitrate	(NO ₃)	<u>0.44</u> mg/L
Phosphate-ortho	(PO ₄)	<u>0.30</u> mg/L
Sulfate	(SO ₄)	<u>67</u> mg/L

Trace Inorganics :		
Aluminum	(Al)	<u><0.01</u> mg/L
Copper	(Cu)	<u>0.001</u> mg/L
Iron	(Fe)	<u>0.075</u> mg/L
Lithium	(Li)	<u>0.018</u> mg/L
Manganese	(Mn)	<u><0.001</u> mg/L
Strontium	(Sr)	<u>0.270</u> mg/L
Zinc	(Zn)	<u><0.005</u> mg/L

Antimony	(Sb)	<u>< 1.0</u> µg/L
Arsenic	(As)	<u>4.16</u> µg/L
Barium	(Ba)	<u>75.1</u> µg/L
Beryllium	(Be)	<u>< 1.0</u> µg/L
Cadmium	(Cd)	<u>< 1.0</u> µg/L
Chromium	(Cr)	<u>< 1.0</u> µg/L
Lead	(Pb)	<u>< 1.0</u> µg/L
Mercury	(Hg)	<u>-</u> µg/L
Nickel	(Ni)	<u><1.0</u> µg/L
Selenium	(Se)	<u>< 5.0</u> µg/L
Thallium	(Tl)	<u>< 1.0</u> µg/L

Bacteriological Quality : Distribution System

Meets U.S.E.P.A. drinking water standards:

TC - 0.00%; E. coli - Absent

Organics :

Atrazine	<u>-</u>	µg/L
----------	----------	------

Metolachlor	<u>-</u>	µg/L
-------------	----------	------

Brent Paine

Biologist I