

METROPOLITAN UTILITIES DISTRICT OF OMAHA
REPORT OF WATER ANALYSIS

Platte West Plant

Monthly Averages

Source: Finished Water

Date: August 2026

Temperature	<u>18.4</u>	° C
Turbidity (NTU)	<u>0.03</u>	Units
Total Organic Carbon	<u>1.6</u>	mg/L
Color	<u>1</u>	Units
Dissolved Oxygen (O ₂)	<u>6.3</u>	mg/L
Langelier Index	<u>1.11</u>	
UV-ABS @ 254 nm	<u>5.0</u>	ABS/m
Specific Conductance @ 25 °C	<u>412</u>	mmhos
Dissolved Solids (Calculated)	<u>322</u>	mg/L

Silica (SiO ₂)	<u>28</u>	mg/L
----------------------------	-----------	------

pH	<u>8.90</u>	mg/L
----	-------------	------

Alkalinity (CaCO ₃)		
Phenolphthalein (P)	<u>14</u>	mg/L
Total (M)	<u>113</u>	mg/L

Total Hardness (CaCO ₃)	<u>132</u>	mg/L
Carbonate	<u>113</u>	mg/L
Non-carbonate	<u>19</u>	mg/L

Nitrogen (N)		
Ammonia	<u><0.05</u>	mg/L
Nitrite	<u><0.02</u>	mg/L
Nitrate	<u>0.42</u>	mg/L

Chlorine (Cl ₂)		
Free Residual	<u>0.08</u>	mg/L
Total Residual	<u>2.46</u>	mg/L

Surfactants (MBAS)	<u>-</u>	mg/L
--------------------	----------	------

Trace Inorganics:		
Iron (total)	<u><0.02</u>	mg/L
Iron (dissolved)	<u>-</u>	mg/L
Manganese (total)	<u><0.02</u>	mg/L
Manganese (dissolved)	<u>-</u>	mg/L

Cations :		
Calcium	(Ca)	<u>39</u> mg/L
Magnesium	(Mg)	<u>8.3</u> mg/L
Sodium	(Na)	<u>30</u> mg/L
Potassium	(K)	<u>9.4</u> mg/L

Anions :		
Bicarbonate	(HCO ₃)	<u>104</u> mg/L
Carbonate	(CO ₃)	<u>16.8</u> mg/L
Hydroxide	(OH)	<u><0.1</u> mg/L
Fluoride	(F)	<u>0.68</u> mg/L
Chloride	(Cl)	<u>16</u> mg/L
Bromide	(Br)	<u>0.02</u> mg/L
Nitrite	(NO ₂)	<u><0.07</u> mg/L
Nitrate	(NO ₃)	<u>1.86</u> mg/L
Phosphate-ortho	(PO ₄)	<u>0.32</u> mg/L
Sulfate	(SO ₄)	<u>67</u> mg/L

Trace Inorganics :		
Aluminum	(Al)	<u><0.01</u> mg/L
Copper	(Cu)	<u>0.001</u> mg/L
Iron	(Fe)	<u><0.02</u> mg/L
Lithium	(Li)	<u>0.018</u> mg/L
Manganese	(Mn)	<u><0.02</u> mg/L
Strontium	(Sr)	<u>0.267</u> mg/L
Zinc	(Zn)	<u><0.005</u> mg/L

Antimony	(Sb)	<u>< 1.0</u> µg/L
Arsenic	(As)	<u>4.32</u> µg/L
Barium	(Ba)	<u>72.8</u> µg/L
Beryllium	(Be)	<u>< 1.0</u> µg/L
Cadmium	(Cd)	<u>< 1.0</u> µg/L
Chromium	(Cr)	<u>< 1.0</u> µg/L
Lead	(Pb)	<u>< 1.0</u> µg/L
Mercury	(Hg)	<u>-</u> µg/L
Nickel	(Ni)	<u>1.06</u> µg/L
Selenium	(Se)	<u>< 5.0</u> µg/L
Thallium	(Tl)	<u>< 1.0</u> µg/L

Bacteriological Quality : Distribution System

Meets U.S.E.P.A. drinking water standards:

TC - 0.00%; E. coli - Absent

Organics :

Atrazine	<u>-</u>	µg/L
Metolachlor	<u>-</u>	µg/L

Chad Juszyk

Water Analyst I